

Inspection Report - CO2 Fire Extinguisher Inspection Checklist (Inspection UID - I/MHC/PRE/CFE/26/00049)

Inspection Information

Inspection Type	C02 Fire Extinguisher Inspection Checklist	Inspection Status	Inspection requested
Site Name	Galeville	Asset UID	TRANSFERYARD/MHC/CO2/11
Asset	Co2	Non Oqsha Assets	
Created on	16-Mar-2026 07:32:02 PM		

Sections

Inspection checks

Company name: My Home Constructions Private Limited	Contractor name: Sudhir Pradhan D - MHC
--	--

Attachments



Equipment Status

Equipment Status at Site: In Site	Equipment Usage Status: In Usage
--	---

Check Points

Is the extinguisher body free from dents, rust, or damage?: Yes	Is the label or marking legible and displaying the extinguisher type, operating instructions, and capacity?: Yes	Is the CO2 horn and discharge tube intact and free from cracks or damage?: Yes	Is the extinguisher visually free of leaks, frost, or condensation?: Yes
For extinguishers without a gauge, does the weight match the manufacturer's specifications?: Yes	Are the safety pin and tamper seal intact and securely in place?: Yes	Is the discharge hose free from cracks, kinks, or blockages?: Yes	Is the nozzle free from obstruction and securely attached?: Yes

Is the extinguisher placed in a designated, easily accessible location?: Yes	Is the extinguisher free from obstructions or barriers?: Yes	Is the extinguisher mounted securely on a bracket or stand at the recommended height?: Yes	Is the extinguisher located near potential fire hazards and protected from adverse conditions?: Yes
For hydrostatic testing, is the extinguisher within its test interval (usually 5 years for CO ₂ extinguishers)?: Yes	Is the hydrostatic test certificate available and up to date?: Yes	Are all site personnel aware of the extinguisher's location and trained in its operation?: Yes	

Signatures

Inspected by: Sudhir Pradhan D - MHC at 16-Mar-2026 07:31 PM.	Checked by: NA	Verified by: NA	Approved by: NA
---	-----------------------	------------------------	------------------------

Inspection History

Created On	Created By	Comment	Attachments
16-Mar-2026 07:32:02 PM	Alec Toribio	A new record was created: Site set to 'Precast Plant' Asset Type set to 'Safety equipment' Inspection Type set to 'C02 Fire Extinguisher Inspection Checklist' Status set to 'Inspection requested' Asset set to 'Co2'	
16-Mar-2026 07:32:02 PM	Alec Toribio	Inspection has been assigned to PAVAN KUMAR MHC at the Checked by stage.	