

## Electrical DB Checklist

Ref No.: PI/EHS/C/25  
Issue date: 05/05/25  
Rev No: 00

### Inspection Information

<b>Name of the Project</b>	Animas	<b>Location of work</b>	T1F4B3
<b>Inspection Date</b>	18-Mar-2026 08:09:50 PM	<b>Inspection Due Date</b>	18-Mar-2026
<b>Tag No Or Db No</b>	823643498		

### Inspection Type Attachment



### Checklist

Description	Yes	No	N/A	Observation details
1. Check if the marking done for DB is completed as per shop drawing	Yes			Electrical DB Checklist
2. Check the location of DB as per coordinated drawing		No		Electrical DB Checklist
3. Check if DB is of approved make (schneider)			N/A	Electrical DB Checklist
4. Check if Anchor fastener is tightened properly & is of approved brand				
5. Check if the DB which is painted and finished is without any Dent and Scratch				
6. Check if Fire Extinguisher is near by the DB				
7. Check monthly inspection tag is done				
8. Check if welding and joints satisfactory				
9. Check if work method statement is submitted				
10. Check the fire extinguisher is having proper pressure				
11. Check if DB is fabricated in Factory and not in Site				
12. Check if proper barrication and Signage is displayed				
13. Check if rubber mat is placed below the DB board				
14. Check the industrial power plugs are in good condition				
15. Check if all the MCB are properly working				
16. Pre-check of earthing				

### Overall observation

<b>Acceptable (Yes/No):</b> Yes	If not acceptable - Equipment removed from site(Date): 01-Mar-2026	Corrective/Preventive action taken(Date): 31-Mar-2026
---------------------------------	--	---

### Inspection Team

Inspected by	Name	Date	Status
Contractor Maintenance Rep.	Hebert Eaton	18-Mar-2026 08:10:27 PM	Signed
Contractor Site EHS Officer			Unsigned
PMC Site Manager			Unsigned

### Inspection History

Created On	Created By	Comment	Attachments
18-Mar-2026 08:10:27 PM	Hebert Eaton	Hebert Eaton has Inspected.	