


# Fire Extinguisher Inspection Checklist

Ref No.: I/WWN/JPM/FEI/26/00001  
Issue date: 05/05/25  
Rev No: 00

### Inspection Information

<b>Name of Site/Location</b>	Animas	<b>Frequency</b>	
<b>Name Of Contractor</b>		<b>Responsible for checks</b>	
<b>Date of First Deployment</b>		<b>Checked by &amp; date during site EHS Risk Evaluation</b>	
<b>Date of Inspection</b>	18-Mar-2026 08:12:51 PM	<b>Machine Serial No:</b>	

### Inspection Type Attachment



### Checklist

Description	Yes	No	N/A	Observation Details
1.Condition of the extinguisher (Clean and Tidy)				
2.Physical appearance for corrosion.				
3.Safety pin in position				
4.Condition of discharge nozzle (any blockage/damage)				
5.Condition of hose(any leakage/broken)				
6.Availability of visual board.				
7.All the indicator gauges in working condition.				
8.Refill date of extinguisher is expired				
9.Cylinder weight verify (If the gross weight of the cylinder is reduced by 10% then cylinder need to be refilled).				
10. Identification number of extinguisher				
11.Location of extinguisher to be fixed				
12.All cylinders should be as per IS-15683-2006.				

### Overall Observation

<b>Acceptable (Yes/No):</b> N/A	If not acceptable - Equipment removed from site(Date) : NA	Corrective/Preventive action taken on (Date) : NA
---------------------------------	--	---

### Inspection Team

Inspected by	Name	Date	Status
Contractor's Supervisor			Unsigned
Site EHS Officer			Unsigned

### Inspection History

Created On	Created By	Comment	Attachments